

टेलीफोन: : 22072512
Telephone

ईमेल: hpl1@cpri.in

यक्तिगत रूप से/पंजीकृत डाक से/ त्रि डाक द्वारापावती पत्र
In person / By Regd. Post / By Courier/By speed post with Ack. Due
केन्द्रीय विद्युत अनुसंधान संस्थान , बेंगलूर - 560 080
CENTRAL POWER RESEARCH INSTITUTE, BENGALURU-560 080
उच्च शक्ति प्रयोगशाला/HIGH POWER LABORATORY

सं/No.HPL/J/1/2022

Date: 29.06.2022

स्वामिन्/To

M/s. Lecon Energetics Pvt. Ltd.,
484, B&C, 14th Cross Road, near BMTD Depot,
Peenya Industrial Area, Phase IV, Bengaluru - 560058

Kindly Attention: Mr. M A Kulkarni

वषय/ Sub :- परीक्षण दस्तावेज / Test Document(s) Report No. CPRIBLRHPL22T0062

महोदय/ Dear Sir ,
हमारी प्रयोगशाला में

..... को आपके
..... पर संचालित परीक्षण के संबंध में निम्नांकित दस्तावेज संलग्न हैं।
Please find enclosed Test Report with the details Mentioned below.


TEST REPORT NO & DATE	SAMPLE DETAILS	TEST CONDUCTED	DATE OF TEST	FINAL (No)	ADDITIONAL COPY (No)
CPRIBLRHPL 22T0062 Dt.29.06.2022	12kV, 1250A, VCB Panel	Short time withstand and peak withstand current tests	11 April 2022	one	Nil

दस्तावेजों की पावती भेजें।

Please acknowledge receipt of the document(s).

P.S :Customer to remove the tested sample within 30 days from the date of completion of testing, failing which the sample will be disposed off by CPRI as per its policy.

Yours faithfully


Joint Director/Additional Director

CENTRAL POWER RESEARCH INSTITUTE



CPRI

TEST REPORT

Test Report Number : CPRI BLRHPL22T0062 **Date:** 29 June 2022

Name and Address of the Customer : M/s. Lecon Energetics Pvt. Ltd.,
484, B&C, 14th Cross Road, near BMTC Depot,
Peenya Industrial Area Phase IV, Bengaluru, 560058.

Name and Address of the Manufacturer : M/s. Lecon Energetics Pvt. Ltd.,
484, B&C, 14th Cross Road, near BMTC Depot,
Peenya Industrial Area Phase IV, Bengaluru, 560058.

Particulars of sample tested : 12kV, 1250A, VCB Panel
Type : Indoor
Description of test sample : Refer sheet 2 of 6
Serial Number : EW 528/1/2021-2022
Number of samples tested : One
Date(s) of Test(s) : 11 April 2022
CPRI Sample code Number(s). : HPL22S0077
Particulars of tests conducted : Short time withstand and peak withstand current tests
Test in accordance with Standard/Specification : As per Clause 7.6 of IEC 62271-200:2021
Sampling Plan : Nil
Customer's Requirement : Nil
Deviations if any : Nil

Name of the witnessing persons
Customers representative : Mr. M. A. Kulkarni
Mr. Y. Phaneendra Kumar
Other than customer's representatives : None
Test subcontracted with address of the laboratory : Nil
Documents constituting this report (in words)
Number of Sheets : Six
Number of Oscillogram(s) : Two
Number of Graph(s) : Nil
Number of Photograph(s) : Two
Number of Test Circuit Diagram(s) : Two
Number of Drawing(s) : Four

M. Rajkumar
(Rajkumar M)
Test Engineer



S. Sudhakara Reddy
(S. Sudhakara Reddy)
Head of Division
Reviewed and Authorized by

ULR-TC5452220HPLT0062F
Discipline: Electrical Testing
Group: Transmission line
equipment and accessories

HIGH POWER LABORATORY
P. B.NO. 8066, SADASHIVANAGAR P.O
PROF. SIR.C.V. RAMAN ROAD, BENGALURU-560 080, INDIA
Tele: + 91 (0) 80-22072511

Sheet 1 of 6

CENTRAL POWER RESEARCH INSTITUTE



TEST REPORT

Test Report Number: CPRI BLRHPL22T0062

Date: 29 June 2022

DESCRIPTION OF SAMPLE TESTED

(As assigned by the manufacturer)

Sample	: 12kV, 1250A, VCB Panel
Type	: Indoor
Serial number	: EW 528/1/2021-2022
Designation	: VCB Panel
Number of phase	: Three phase
Class	: Indoor
Rated voltage	: 12 kV
Rated normal current	: 1250 A
Rated insulation level	: 28 kV RMS / 75 kV peak
Frequency	: 50 Hz
Rated short time withstand current and duration of main circuit	: 40 kA RMS for 3.0 seconds
Rated Peak withstand current of main circuit	: 100 kA peak
Rated short time withstand current and duration of earth circuit	: 20 kA RMS for 1.0 second
Rated Peak withstand current of earth circuit	: 50 kA peak

M Rajkumar
(Rajkumar M)
Test Engineer

CENTRAL POWER RESEARCH INSTITUTE

TEST REPORT

Test Report Number: CPRIBLRHPL22T0062

Date: 29 June 2022

SUMMARY OF TESTS CONDUCTED

1. Tests conducted : Short time withstand and peak withstand current tests
2. Rating for which tested : 40 kA RMS for 3.0 seconds for main circuit
20 kA RMS for 1.0 second for earth circuit
3. Schedule of tests

Tests Conducted	Clause Numbers	Sheet
Short time withstand and peak withstand current tests	Clause 7.6 of IEC 62271-200:2021	5 of 6
Dielectric tests	Clause 7.2.12 of IEC 62271 -1:2017	5 of 6
Measurement of the resistance of circuits	Clause 7.4.4 of IEC 62271 -1:2017	5 of 6

4. Oscillogram Numbers : CPRIBLRHPL22T0062S003, S006
5. Graph Numbers : Nil
6. Photograph Numbers : CPRIBLRHPL22T0062P01, P02
7. Test Circuit Diagram Numbers : CPRIBLRHPL22T0062TCD01, TCD02
8. Drawing Numbers : Refer sheet 4 of 6

M. Rajkumar
(Rajkumar M)
Test Engineer

CENTRAL POWER RESEARCH INSTITUTE

TEST REPORT

Test Report Number: CPRIBLRHPL22T0062

Date: 29 June 2022

LIST OF DRAWINGS

Drawing Numbers

The manufacturer has guaranteed that the sample submitted for the test(s) has been manufactured in accordance with the following drawings

Sl. No.	Drawing Number	Sheet Number	Revision Number
1	EW528/1/01	1 OF 3	0
2	EW528/1/02	2 OF 3	0
3	EW528/1/03	3 OF 3	0
4	1VYN304001-BT	2 OF 2	A

It is verified that these drawings adequately represent the sample tested. Verification of this drawing by CPRI is limited to dimensional check only wherever possible.

M. Rajkumar
(Rajkumar M)
Test Engineer

CENTRAL POWER RESEARCH INSTITUTE

TEST REPORT

Test Report Number: CPRI BLRHPL22T0062

Date: 29 June 2022

TEST RESULTS

Test conditions

Source	: Short-circuit generator and High current transformer
Number of phases	: Three (Test on main circuit), Two (Test on single phase earth circuit)
Frequency	: 50 Hz
Test samples	
Condition before test	: New
Mounting arrangement	: Refer Photograph No. CPRI BLRHPL22T0062P01
Test details	
Test circuit drawing number	: CPRI BLRHPL22T0062TCD01 (Test on main circuit) : CPRI BLRHPL22T0062TCD02 (Test on single phase earth circuit)
Short-circuit point	: Grounded

a) Test on main circuit:

Oscillogram Number	Peak Current (kA)	RMS Current (kA)				Duration (seconds)
		I ₁	I ₂	I ₃	I _{avg}	
CPRI BLRHPL22T0062S003	100.2	44.0	42.8	41.6	42.8*	3.050
[*Equivalent to 43.1 kA RMS for 3.0 seconds]						

b) Test on single phase earth circuit:

Oscillogram Number	Peak Current (kA)	RMS Current (kA)	Duration (seconds)
CPRI BLRHPL22T0062S006	53.9	22.1*	0.826
[* Equivalent to 20.1 kA RMS for 1.0 second]			

c) Dielectric Tests:

Condition of sample	Observation	
	Applied Voltage across the interrupters with breaker opened.	Applied Voltage between live parts and ground with breaker closed.
After test	28.0 kV RMS Withstood for 1.0 minute	28.0 kV RMS Withstood for 1.0 minute

d) Measurement of the resistance of main circuit:

Condition of sample	Ambient temperature in °C	Contact resistance in μΩ		
		Pole-1	Pole-2	Pole-3
Before test	36	77.2	78.0	79.1
After test	28	70.1	70.1	70.4

Observations during test	: No abnormalities.
Observations After test	: 1) Circuit Breaker operable on its first attempt. 2) No visible external damage.

Conclusion: The sample tested complies with the requirements of clause 7.6 of IEC 62271-200:2021 for the test(s) conducted.

M Rajkumar
(Rajkumar M)
Test Engineer

CENTRAL POWER RESEARCH INSTITUTE

TEST REPORT

Test Report Number: CPRI BLRHPL22T0062

Date: 29 June 2022

NOTE

- The Test results relate only to the sample(s) tested.
- Publication or reproduction of this Test Report /Test Certificate in any form other than by complete set of the whole Test Report /Test Certificate and in the language written is not permitted without the written consent of CPRI.
- Any Corrections/erasure invalidates the Test Report/Test Certificate.
- Any anomaly/discrepancy in the Test Report / Test Certificate should be brought to the notice of CPRI within 45 days from the date of issue.
- All documents constituting the Test Report/Test Certificate are stitched together with a continuous silk thread/silk ribbon, the two ends of which have been brought over the front sheet of the Test Report/Test Certificate and sealed with a CPRI logo printer paper sticker/embossed.
- NABL has Accredited this laboratory as per ISO/IEC 17025: 2017, vide certificate no.TC-5452 for the tests carried out.



TC-5452

M. Rajkumar
(Rajkumar M)
Test Engineer

-----End of Test Report-----

CENTRAL POWER RESEARCH INSTITUTE

TEST REPORT




CPRI

Test Report Number : CPRIBLRHPL22T0062

Date : 29 June 2022

TEST RESULTS



Oscillogram Number : CPRIBLRHPL22T0062S003

M. Rajkumar

(Rajkumar M)
Test Engineer

CENTRAL POWER RESEARCH INSTITUTE

TEST REPORT




CPRI

Test Report Number : CPRI BLRHPL22T0062

Date : 29 June 2022

TEST RESULTS



Oscillogram Number : CPRI BLRHPL22T0062S006

M Rajkumar

(Rajkumar M)
Test Engineer

CENTRAL POWER RESEARCH INSTITUTE



TEST REPORT

Test Report Number: CPRI BLRHPL22T0062

Date: 29 June 2022



Photograph Number: CPRI BLRHPL22T0062P01

Mounting arrangement before test

M. Rajkumar
(Rajkumar M)
Test Engineer

CENTRAL POWER RESEARCH INSTITUTE



TEST REPORT

Test Report Number: CPRIBLRHPL22T0062

Date: 29 June 2022



Photograph Number: CPRIBLRHPL22T0062P02

Condition of sample after test

M. Rajkumar
(Rajkumar M)
Test Engineer


CENTRAL POWER RESEARCH INSTITUTE



TEST REPORT

Test Report Number: CPRI BLRHPL22T0062

Date: 29 June 2022



Test Circuit Diagram Number: CPRI BLRHPL22T0062TCD01

M. Rajkumar
(Rajkumar M)
Test Engineer


CENTRAL POWER RESEARCH INSTITUTE



TEST REPORT

Test Report Number: CPRI BLRHPL22T0062

Date: 29 June 2022



LEGEND

- S 2500 MVA short circuit generator
 R_n Generator neutral grounding resistor
MCB Master circuit breaker
MS Make switch
X Variable current limiting reactor
T 300 kA testing transformer
VD Voltage divider
CT1, CT2 & CT3 Measuring current transformer
A Apparatus under test
 I_1, I_2, I_3 Currents recorded on primary side of 300 kA transformer
RG Rogowski Coil

CPRI HIGH POWER LABORATORY
BANGALORE

Schematic diagram of test circuit

Drg. No. CRTL/HPL/ISC 22 A





Test Circuit Diagram Number: CPRI BLRHPL22T0062TCD02

M. Rajkumar

(Rajkumar M)
Test Engineer

IF IN DOUBT, ASK

रिपोर्ट क्रमांक
से संबंधित दस्तावेज
Document Pertaining to
Report No. **CPR/BCHPL/22/0062**



Note: All Dimensions are in mm
& Tolerance $\pm 5\text{mm}$

M. K. Kulkarni
परीक्षण अभियन्ता / Test Engineer
उच्च शक्ति प्रयोगशाला / H.P. LAB
सी. पी. आर. आई. / CPRI
बेंगलुरु / Bengaluru

संयोजक को सत्यापन जहाँ
कहीं भी संभाव हो सके विमर्श जांच तक ही सीमित है।
THE VERIFICATION OF THIS DRAWING
BY CPRI IS LIMITED TO DIMENSIONAL
CHECKS ONLY WHEREVER POSSIBLE

TITLE: GENERAL ARRANGEMENT FOR
12KV, 1250 AMPS, 40KA FOR 3SEC VCB PANEL

DATE: 10.03.2022
MODEL NO:
VCB PANEL 12KV-40KA3-1250A

W.O.NO: EW528/1/2022

DRG.NO: EW528/1/01

DRN	Phanendra
DGN	Phanendra
CHD	Phanendra
APP	M.A. Kulkarni

LECON ENERGETICS

No. 484 B&C, IV Phase, Opp. BMTC Depot No.9
Peenya Industrial Area, Bangalore - 560058, Karnataka,
E-MAIL ID sales@leconsystem.com, lecongm@gmail.com
PH. NO. 9449041220. WEB SITE: www.leconenergetics.com



QMS/DES/FORM/06

SCALE: NTS



THIS DRAWING IS THE PROPERTY OF LECON ENERGETICS AND IS NOT TO BE COPIED OR USED WITHOUT ITS WRITTEN PERMISSION

SHEET 1 OF 3
REV 0

Note: All Dimensions are in mm
& Tolerance : $\pm 5\text{mm}$



A: TEMERORARY LINKS FOR TESTING PURPOSE

[illegible]

SL.NO	DESCRIPTION
01	METERING CHAMBER
02	BREAKER CHAMBER
03	BUSBAR CHAMBER
04	CABLE CHAMBER
05	EPDXY BUSHINGS (R.Y.B)
06	EPDXY INSULATORS Ø95 X 130
07	MAIN EARTHING--IRx40xØ95CU
08	VCB
09	RACKING MECHANISM
10	BASE FRAME
11	INCOMING BUSBAR SIZE--IRx80x100CU (CURRENT INJECTING POINT)
12	VENT FLAPS (3 NOS)
13	PROVISION FOR BREAKER RACK IN DUT
14	VIEWING WINDOW
15	TOP/BOTTOM INSULATOR SUPPORT --795x150x3MM--2 NOS

क्याही भी संभाव होमर्फ वमरु 100 मांय तसुड वुव है 1600
 THE VERIFICATION OF THIS DRAWING
 BY CPRLS LIMITED TO DIMENSIONAL
 ARRANGEMENT FOR

800

रिपोर्ट क्रमांक
से संबंधित दस्तावेज
Document Pertaining to
Report No. ~~CPRI/2012/11~~

TITLE: GENERAL ARRANGEMENT FOR 12KV, 1250 AMPS, 40KA FOR 3SEC VCB PANEL		W.O.NO: EW528/1/2022	DRN/ Phantendra	Phantendra	
DATE: 0.03.2022		MODEL NO: VCB PANEL 12KV-40KA3-1250A	DGN/ Phantendra	Phantendra	
		DRG.NO: EW528/1/02	CHD/ Phantendra	Phantendra	
			APP/ M.A.Kulkarni	M.A.Kulkarni	
QMS/DES/FORM/06		SCALE: NTS		No.484 B&C, IV Phase, Opp. BMTC Depot No.9 Peenya Industrial Area, Bangalore - 560058, Karnataka, E-MAIL ID sales@leconsystem.com, lecongm@gmail.com PH.NO.9449041220. WEB SITE: www.leconenergetics.com	

THIS DRAWING IS THE PROPERTY OF LECON ENERGETICS AND IS NOT TO BE COPIED OR USED WITHOUT ITS WRITTEN PERMISSION

REV 0	SHEET 2 OF 3
----------	-----------------

1	2	3	4	5	6	7	8	9	10
---	---	---	---	---	---	---	---	---	----

Note: All Dimensions are in mm
& Tolerance $\pm 5\text{mm}$

LECON ENERGETICS PVT LTD

MODEL NO: VCB PANEL-12KV-40KA3-1250A

PRODUCT DESCRIPTION : VCB PANEL

RATING : 12KV, 1250 AMPS, 40KA3, 50Hz

WORKS NO : EW528/1/2022

Mfd by:

LECON ENERGETICS PVT LTD

No.484B&C, IV Phase, Opp. BMTC Depot No.9, Peenya Industrial Area, Bangalore - 560058, Karnataka

E'MAIL ID sales@leconsystem.com, lecongmg@gmail.com, PH.NO.9449041220. WEB SITE: www.leconenergetics.com

Name Plate

SPECIFICATIONS: All Dimensions are in mm

1. Frame structure: 2 mm thickness

2. All Doors: 2MM thk, Back and side doors are removable & base arrangement with ISMC75*40*5 Channel, Handles are provided for back doors

3. Paint shade: #RAL 7032, as per IS 5.

4. Power cable entry from bottom through 3mm thickness Aluminum Gland plate

5. Protection: IP54

6. Clearance from the rare ends Required 1000mm

7. Bus bar termination - 80X6, 2 runs CU.

8. Earthing Busbar - 40X6 CU.

9. Weight @ 700 kgs (approximately)

10. Overall dimensional Tolerance: $\pm 5\text{mm}$

सभी आरक्षणों का उत्तर रखादिन का सत्यापन जहाँ
कहीं भी संभाव्य होस्तिक विमीय जांच तक ही सीमित है।
THE VERIFICATION OF THIS DRAWING
BY CPRI IS LIMITED TO DIMENSIONAL
CHECKS ONLY. WHEREVER POSSIBLE

M Raj Kumar
परिक्षण अभियन्ता / Test Engineer
उच्च शक्ति प्रयोगशाला / H.P. LAB
सो. पी. आर. आई. / CPRI
बंगलुरु / Bengaluru

रिपोर्ट क्रमांक.....
से संबंधित दस्तावेज
Document Pertaining to
Report No. CPRI BURL HPL 22T0062



TITLE: GENERAL ARRANGEMENT FOR 12KV,1250 AMPS,40KA FOR 3SEC VCB PANEL		W.O.NO: EW528/1/2022		DRN Phaneendra	
DATE: 10.02.2022	MODEL NO: VCB PANEL 12KV-40KA3-1250A	DRG.NO: EW528/1/03		DGN Phaneendra	
QMS/DES/FORM/06		SCALE: NTS		APP M.A.Kulkarni	
THIS DRAWING IS THE PROPERTY OF LECON ENERGETICS AND IS NOT TO BE COPIED OR USED WITHOUT ITS WRITTEN PERMISSION				SHEET REV 3 OF 3 0	


◆

LECON ENERGETICS


No.484 B&C. IV Phase, Opp. BMTc Depot No.9
Peenya Industrial Area, Bangalore - 560058, Karnataka,
E'MAIL ID sales@leconsystem.com,lecongm@gmail.com
PH.NO.9449041220. WEB SITE:www.leconenergetics.com

LECON ENERGETICS
No.484 B&C, IV Phase, Opp. BMTC Depot No.9
Peenya Industrial Area, Bangalore - 560058, Karnataka,
E'MAIL ID sales@leconsystem.com, lecongmg@gmail.com
PH.NO.9449041220. WEB SITE: www.leconenergetics.com

Rev
A 10/18
SH.2
REVISED



FRONT VIEW



रिपोर्ट क्रमांक... से संबंधित दस्तावेज
Document Pertaining to
Report No. C.PRI.BKR.HP.122 To062

परिक्षण अभियन्ता / Test Engineer
उच्च शक्ति प्रयोगशाला / H.P. LAB
सी. पी. आर. आई. / CPRI
बंगलुरु / Bengaluru

Standard tolerances for machining and forming:
Lengths and angle dimensions DIN ISO 2768 T 1
"fine" ☐ "medium" ☐ "coarse" ☐
Form and position: DIN ISO 2768 T 2

Material	Type	Weight	Surface	- kg	- mm	Surface code	Drawing status
INABB	A	INABB	INABB	INABB	INABB	INABB	INABB
Revision	EC No.	Location	Date	Responsible	Name	Title	Sub title
Drawn	INABB	INABB	2008/22	JMN	JMN	MOUNTING DIM.DETAIL 1250A	
Checked	INABB	INABB	2008/22	PDD	PDD		
Approved	INABB	INABB	2008/22	PDD	PDD		
ABB	ABB Technology Ltd.						
Drawing No. 1VYN304001-BT							Scale 1:20
							Language EN
							Format A3
							Sheet No. 2/2

संपि... का सत्यापन जह...
क... जांच तक ही सीमित है।
THE VERIFICATION OF THIS DRAWING
BY CPRI IS LIMITED TO DIMENSIONAL
CHECKS ONLY. WHEREVER POSSIBLE